



NOTES:

1. All flatwork shall use Class A (minimum 3,000 psi at 28 days) concrete unless otherwise detailed or specified. Concrete requirements for flatwork of any other class shall be labeled on the plans and called out in the specifications.
2. No reinforcing bars will be closer than three inches (3") to edge of concrete.
3. 1/2" preformed expansion joint material shall be placed at intervals not to exceed thirty feet (30') in the slab or as directed by the engineer. Scoring joints (dummy joints) shall be placed in slab with jointing tools at intervals not to exceed ten (10') feet.
4. 1" sand cushion shall be wetted and forms oiled prior to placing any concrete.
5. Refer to City of Amarillo Driveway and Parking Manual (latest edition) for additional information.

 <p>CITY OF AMARILLO ENGINEERING DEPARTMENT</p>	Drawn by: rjh	Date: 8/24/2010	<p>Description</p> <p>Standard Residential Driveway Alterations (No Existing Sidewalk)</p>
	Designed by: rjh	Job No:	
	Path:		
	Scale: 1" = 10'	Sheet 1	