



## AMARILLO BI-CITY-COUNTY HEALTH DISTRICT

Amarillo, Canyon, Potter County, Randall County

CITY OF AMARILLO, P. O. Box 1971, Amarillo, TX, 79105-1971

### Swimming Pool Violation Enforcement Guide

#### Immediate Closure:

- pH less than 7.0 or greater than 7.8
- Water clarity insufficient to see main drain grate
- Disinfection equipment inoperable
- Recirculation equipment inoperable
- Missing or inoperable safety equipment
- Broken or unsecured main drain grate
- Electrical or other hazards
- Bacterial or chemical contamination
- EPI outbreak
- Self-latching gate does not work
- No vacuum covers
- High chlorine (8 ppm) or bromine (12 ppm) levels
- 

#### Abatement within 24 hours:

- Cyanuric acid higher than 100 ppm
- Unsanitary or inoperable restrooms
- Test kit missing
- Pool appearance (dirty or debris)
- Handrail or ladder loose or no protective cups
- "NO DIVING" in 4" letters missing
- Fence Breach
- Broken spa timer

#### Abatement within 21 days:

- pH feeders inoperable or missing
- Flow meter inoperable or missing
- Flow rate reading more than 10% variation from design flow
- Skimmer grates inoperable or missing
- Water level control mechanism inoperable or missing
- Shower inoperable or missing on Class A and B pools
- Thermometer on spa inoperable or missing
- Algae growth
- Deck, curb or tile repair needed
- Depth markings not correct
- Pool rules not posted
- Insufficient lighting
- Maintenance log inadequate
- No antisiphoning device on hose bibs
- No air gap on waste line
- DE separator missing