


Longitudinal Section Through Curb & Gutter
Typical Expansion Joint Details

NOTES:

1. All flatwork shall use Class A (minimum 4,000 psi at 28 days) Concrete unless otherwise detailed or specified. Concrete requirements for flatwork of any other class shall be labeled on the plans and called out in the specifications.
2. No reinforcing bars will be closer than three (3") inches to edge of concrete.
3. $\frac{1}{2}$ " preformed expansion joint material shall be placed at intervals not to exceed thirty feet (30') in the curb and gutter or as directed by the engineer. Scoring joints (dummy joints) shall be placed in curb and gutters with jointing tools at intervals not to exceed five (5') feet.

| | | | | |
|--|---------------------|--------------------|--|---|
| <p>CITY OF AMARILLO</p>  <p>ENGINEERING DEPARTMENT</p> | Drawn by: rjh | Date: 8/24/2010 | | <p>Description</p> <p>8" Reinforced Concrete Curb & Gutter</p> |
| | Designed by: rjh | Job No: | | |
| | Path: | | | |
| | Scale: 1" = 10' | Sheet 1 | | |